



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

June 13, 2013

ADDENDUM NUMBER ONE

RFQ # 7469378

TITLE: Purchase and install generator and transfer switch-Armory of Mounted Commands

Closing Date and Time: 6/27/13 at 2:00 PM (Note Change)

Per the issuance of this ADDENDUM #1 (total of 3 pages and a disc with PDF files) the following changes are noted:

Please be advised the Bid Closing Date and Time has been extended:

From: 6/20/13 at 10:30 AM

To: 6/27/13 at 2:00 PM


☒ **Specification Change /Addition / Clarification**

This addendum clarifies/answers questions from pre bid.

Questions concerning this solicitation may be e-mailed to the division of purchases at bidinfo@purchasing.ri.gov no later than June 18, 2013 at 5pm (eastern). Please reference the bid number on all correspondence. Questions should be submitted in a Microsoft word attachment. Answers to questions received, if any, will be posted on the internet as an addendum to this solicitation (www.purchasing.ri.gov). It is the responsibility of all interested parties to download this information.

This addendum posts the sign in sheet from the mandatory pre bid held 6/11/13 at 10:30am.

Total of 0 bollards to be installed.



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

Department of Administration
DIVISION OF PURCHASES
One Capitol Hill
Providence, RI 02908-5855

Tel: (401) 574-8100
Fax: (401) 574-8387
Website: www.purchasing.ri.gov

June 13, 2013

ADDENDUM NUMBER ONE
RFQ # 7469378

TITLE: Purchase and install generator and transfer switch-Armory of Mounted Commands

This addendum posts existing/proposed plan, pad detail and wall detail in PDF format.

Is copper wire required on the feeders or can aluminum be used. Copper

Where is the annunciator to be located? Where it meets all electrical and fire codes

Does the existing portable generator wiring system have to be removed completely or just disconnected? Completely removed and cleaned to include fixing holes in wall

The previous generator bids for the armory's (Bristol & Middletown, bid in April) we were directed by addendum to carry an engineering stamp for design drawings. State electrical inspector will require design drawings stamped by an electrical engineer. Please confirm if this cost should be carried by the contractor? It is not clearly defined in the solicitation. Same procedure will apply with this solicitation. Any costs should be included in bid price.

Please clarify the 90 day schedule. This will not be enough time if stamped drawings are required and also most generators have 8 - 10 week lead times after approval. Please advise?

Time frame extended to 120 days. Schedule is meant as a guideline.



State of Rhode Island
Division of Purchases
One Capitol Hill
Providence, RI 02908

"MANDATORY" PRE-BID CONFERENCE SIGN IN SHEET

Mandatory Pre-bid Conference: Any vendor who intends to submit a bid proposal in response to this solicitation must have its designated representative attend the mandatory pre-bid conference. The representative must register at the pre-bid conference and disclose the identity of the vendor whom he/she represents. Because attendance at the pre-bid conference is mandatory, a vendor's failure to attend and register at the pre-bid conference shall result in disqualification of the vendor's bid proposal as non-responsive to the solicitation.

BID NUMBER	7469378
BID TITLE	PURCHASE AND INSTALL GENERATOR & TRANSFER SWITCH-ARMORY OF MOUNTED COMMANDS
PRE-BID DATE AND TIME	JUNE 11, 2013 AT 10:30AM

Purchasing Representative	DAVID CADORET
Mandatory Pre-bid START TIME	10:30
Mandatory Pre-bid END TIME	10:30

COMPANY NAME	COMPANY REPRESENTATIVE	ADDRESS	CONTACT E-MAIL	CONTACT PHONE NUMBER	CONTACT FAX NUMBER	PROPOSAL SUBMITTED (For Purchasing Use Only)
1 Ew Audet	George Robert	169 BAY ST Providence	George.Robert@ewaudet.com	401 467 3510	401 781 8820	
2 Nolin Electric	Joe Therman	W Scituate	Nolin Electric	401-640-0548		
3 CALSON CORP.	STEVE CALOZZA	34 OAKMAN AVE JONASTON	STEVE.C@CALSONCORP.COM	401-272-1100	401-272-0035	
4 Allied Elec	Andrew Giuliano	528 Charles St Providence	Andrew@alliedelec.com	401-351-8800	401-351-8811	
5 Carol Hyatt						
6 State Purchasing	David Goulet					
7						
8						
9						
10						
11						
12						
13						
14						
15						